

### **FLEXIBLE POWER**



#### TITLE:

3183A 3 Core Arctic Flex Power PVC

#### CODE:

SFX/3183AG-3C-1.5-PVC-BLU-U-100

#### **DESCRIPTION:**

100m 3183A 1.5mm Artic Flex Blue PVC (A05V3V3-F 3G1.5)

#### **SUPPLIED AS:**

Reel of 100m

- Can be installed in freezers
- Flexible at sub zero temperatures and even more flexible at room temperatures
- · Polyvinyl chloride plastic has excellent aging properties and will usually exceed a 25-30 year service life
- Blue denotes 240V
- Improved performance and protection against fire

















enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23













# FLEXIBLE POWER CABLE



### **Product Specification**

#### **Cable Construction**

Cable Construction	3 Cores
CPR	Eca
Conductor	Fine Stranded Copper (Class 5)
Overall Diameter (mm)	8.10

#### Insulation

Insulation	CR-PVC	
Insulation Colour	Blue Brown Green/Yellow	

#### **Outer/Jacket Specification**

Jacket	CR-PVC
Overall Colour	Blue
Overall Diameter (mm)	8.10
Jacket Colour	Blue

#### **Electrical Characteristics**

Max Conductor DC resistance @ 20°C	13.30O/km
Rated Temperature (°C)	-20°C to +60°C (Cold bend test -40°C)
Rated Voltage (V)	300/300V


























# FLEXIBLE POWER CABLE



#### MORE INFORMATION:

CLASSIFICATION CRITERIA					
CLASS (ca:cable)	FIRE RATING	SFX COMMENT	CPR GUII	DE <i>Se</i> d	curi-Flex°
Reaction to Fire BS EN ISO 1716 SUBCLASSIFICATIONS FOR EUROC					6 Bca to Dca
A <sub>ca</sub>	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.	(S) SMOKE PRODUCTION	(D) FLAMING DROPLETS	(A) SMOKE ACIDITY
Reaction to Fir	e BS EN 50399		BS EN 50399/BS EN 61034-2	BS EN 50399	BS EN 60754-2
B1 <sub>ca</sub>	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)	d0: No fall of droplets or flaming particles, times for 1200 seconds	a1: Very low acidity (conductivity <2.5 µS/mm & pH >4.3)
B2 <sub>ca</sub>	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)	d1: Fall of droplets or	a2: low acidity
Cca	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.	s1: Low production of slow propagation of smoke s2: Intermediate	flaming particles that persist for less than 10 seconds, timed for 1200 seconds	(conductivity <10 µS/mm & pH >4.3)
D <sub>ca</sub>	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.	production & propagation of smoke s3: None of the above	d2: None of the above	d2: None of the above
Reaction to Fir	e BS EN 60332-1-2				
E <sub>ca</sub>	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 kW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.	Visit us onlin www.securiflex		The Trusted Cable Brand
F <sub>ca</sub>	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	Classes A to E have to be tested by an independent authorised laboratory. Most cables will fall into classes B2ca to Eca. For a cable to meet Aca, B1ca, B2ca or Cca, there also needs to be regular on-going factory audits.		













enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23









